

ANSI/API Standard 607 Seventh Edition – 2016 Fire Test Certificate

Name of Manufacturer:	Cornerstone Valve
Designation of Valve:	FBC2-0100R-00900-00
Size:	1 inch x ¾ inch Reduced
Body/Bonnet Material:	316SS

Test Date:	November 3, 2016
Report/Certificate Number:	216387A
Pressure Rating:	ANSI Class 900
Seat/Stem Seal Material:	PEEK and PTFE/Graphite

The above valve was tested in accordance with the above stated fire test procedure in both flow directions. All of the applicable test parameters were met and external and through leakage measurements were below the allowable limits. Other valves of the same construction may also be qualified according to the requirements of the test specification, Section 7.

This certificate refers to the above mentioned product. This is to certify that the test specimen provided is in conformity with the standard mentioned above. This certificate does not imply assessment of the production of the product.

Laboratory Information

Name:	Yarmouth Research and Technology, LLC
Address:	434 Walnut Hill Road North Yarmouth, ME 04097 USA
Tester:	Matthew Wasielewski, PE info@yarmouthresearch.com www.yarmouthresearch.com (207) 829-5359

