

API6FA Firesafe Certificate of Compliance for

Cornerstone Valve

Series TE1 8" x 6" ANSI 600 Soft Seated Ball Valve

(TE1-0800R-00600-00 Rev. A)

Through Leakage(High Test Pressure) : **PASS**

- During Burn Period(Valve Closed)

External Leakage(High Test Pressure) : **PASS**

- During Burn & Cool Down Period(Valve Closed)

Through Leakage(Low Test Pressure) : **PASS**

- After Cool-Down(Valve in Closed Position)

External Leakage(Low Test Pressure): **PASS**

- After Cool-Down(Valve in Closed Position)

Operation: **PASS**

External Pressure: **PASS**

- After Cool-Down(Valve in Open Position)

OVERALL TEST: **PASS**

Testing was performed in accordance to API 6FA THIRD EDITION, APRIL 1999 Specification for Fire test Valves. Acceptance criteria was defined by API 6FA. Reference Test report TF-TR0048 for results.



**ODIN HEAVY
INDUSTRIES**

David Leggett
Facilities Manager
Issued: 1/12/2016

TF-TC0048 Rev. C